

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2014

2015 MAY 29 AM 10:37

Town of Falkner & Blackjack Water Assn.  
Public Water Supply Name

0700005 + 0050016

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- ☒ Advertisement in local paper (attach copy of advertisement)  
☐ On water bills (attach copy of bill)  
☐ Email message (MUST Email the message to the address below)  
☐ Other \_\_\_\_\_

Date(s) customers were informed: 0/4/ , 2/9/ , 2015

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

- ☐ As a URL (Provide URL \_\_\_\_\_)  
☐ As an attachment  
☐ As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Southern Sentinel & Southern Advocate

Date Published: 4/29/15

CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):  
\_\_\_\_\_

**CERTIFICATION**

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Deyle Griffin Mason  
Name/Title (President, Mayor, Owner, etc.)

5-22-15  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:  
[water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

2014 Annual Drinking Water Quality Report  
Town of Falkner/Blackjack Water Association  
PWS#: 0700005 & 0050016 ✓  
April 2015

TOWN OF FALKNER - WATER SUPPLY

2015 APR 27 PM 4: 14

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Coffee Sand and Ripley Formation Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Falkner have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Colleen Weeks at 662.837.4940. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 7:00 PM at the Falkner City Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

PWS ID#: 0700005 TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2013*	.16	.14 - .16	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2012/14	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2013*	.12	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
<b>Disinfection By-Products</b>								
Chlorine	N	2014	.8	.40- 1	ppm	0	MDRL = 4	Water additive used to control microbes

**PWS ID#: 0050016****TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2011*	.072	.042 - .072	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2011*	5.8	3.6 – 5.8	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011*	.119	.106 - .119	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
82. TTHM [Total trihalomethanes]	N	2014	1.28	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	.80	.5 - .9	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2014.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

NOTICE: The report will not be mail to each customer, however a copy an be obtained at our office.

2015 MAY 29 AM 10:37

# Proof of Publication

**The State of Mississippi**

**Tippah County**

Personally appeared before me a Notary Public in and for said County and State, the undersigned

Tim Watson

who, after being duly sworn, deposes and says that he is the Publisher of the SOUTHERN SENTINEL, a newspaper published in the City of Ripley, in said County and State, and that the

## LEGAL NOTICE

a true copy of which is hereto attached, was published for

1

consecutive weeks in said

newspaper as follows:

**VOLUME**

**NO.**


**DATE**

137

9

4/29/2015


And further, that said newspaper has been published in Ripley, Tippah County, Mississippi for more than one year next preceding the first insertion of the above mentioned legal notice.



Tim Watson


Sworn to and subscribed before me this the

19 DAY OF MAY, 2015



Notary Public, Tippah County, Mississippi

My Commission expires: **05/05/2017**



Printer's Fee

\$ 82.36

2015 MAY 29 AM 10: 37

# Proof of Publication

**The State of Mississippi**

**Benton County**

Personally appeared before me a Notary Public in and for said County and State, the undersigned

Tim Watson

who, after being duly sworn, deposes and says that he is the Publisher of the SOUTHERN ADVOCATE, a newspaper published in the Town of Ashland, in said County and State, and that the

## LEGAL NOTICE

a true copy of which is hereto attached, was published for 1 consecutive weeks in said

newspaper as follows:

VOLUME	NO.	DATE
<u>109</u>	<u>19</u>	<u>4/30/2015</u>
<u>          </u>	<u>          </u>	<u>          </u>
<u>          </u>	<u>          </u>	<u>          </u>
<u>          </u>	<u>          </u>	<u>          </u>

And further, that said newspaper has been published in Ashland, Benton County, Mississippi for more than one year next preceding the first insertion of the above mentioned legal notice.



Tim Watson


Sworn to and subscribed before me this the

19 day of MAY 2015



Notary Public, Benton County, Mississippi

My Commission expires: **05/05/2017**



Printer's Fee \$

## Oakland News

By Mildred Norton  
Community Correspondent

Did you hear about the nice lady who went outside early one cold morning? On her porch was a possum all soiled up. She turned it over and she thought it was dead. She picked it up by the tail and her heater was getting hot so she dropped it in the heater. It was told the heater danced all over the room. Didn't take long to become unsold.

Why talk about revival if we can't fit the pattern. Can we meet in on accord in unity and

expect to meet Jesus. I've heard people say it doesn't matter when or where we meet, we're all trying to go to the same place. Jesus deals with us one by one and how we prepare means everlasting life or hell. There is a miracle in attendance as we worship we bond together Christian to Christian. If we love Jesus we will pray fellowship and obey.

Bro. Don read from Acts, he always preaches so great and attendance is rising. Thanks Bro. Don. Bro. Terry Wilburn led in singing and leading the choir. Thanks, Bro. Terry.

Come to Oakland Baptist Church anytime to worship.

Recently Bill and Kay Winter and Kevin and Hailey and Son Hudson Winter went to Orlando, Florida for a week. They went to Disney Land and enjoyed and had a very good time.

Harmony Baptist Church had a birthday lunch last Sunday for Patty Jackson to celebrate her 90th birthday. Her sons Bill and Jim brought food and Harmony congregation furnished many goodies too. Bro. Don Wilson and Kelton Melton attended the happy event. We all

wish Patty a happy birthday.

Pleasant Bass came to Larry Norton's shop to get a sticker and since Cliff, my late husband, and I love the Basses I hugged his neck. I asked him if his wife cared if I hugged him he said put it in the paper and we'll find out.

We send love and sympathy to the Jerome Roberts family in his death.

Special prayers go to Sonny Street, Linda Smith, Elmer Moeks, Phillip Buse, Bradley Yelverton, Linda Curle and Chloe Thompson. Please pray for our

country and leaders, Elizabeth Reed, Dee Brown, Sonny and Carolyn Street, Faye and Earlene Booker, Ruth Martindale and Ricky, service men and women, Bill and Naomi Devore, Christy Hall, pastor search committee, Julia Edwards, Randy Buse, Francis Brumley, Wanda King, Jeremy Brown and family, Marshall and Daphne Beaty, Anna Hopper, S.A. and Billie Tapp, Chris and Melannie Alfonso, Faye Woods, Cooper McCoy, Corbin Jones, Bill Joyner Jr., Misty Luna, Eugene Shoffner, Natlie Gray, Terry Nelson, Phillip

Buse, Baby Noah Hopper, Buck Childs family, Annie May Henderson family, Nettie Brown, John Rawls family, Massel Appleton, Bryant Scott, Wanda Hunsucker, Ray Sartor family, Rhonda Wright, Jennie Reed, Diane Robinson and family, Amanda Chandler's uncle, Isaac Saucedo, Ruth Anderson's son, Mark Lothenore, Jerome Roberts family, Rickey Martindale's grandson, Jeremy and Judy Brown, Oklahoma City bombing victim's families (20th anniversary), Wanda Hunsucker, Jackie Gray and Rhonda Wright.

## Cotton Plant/Academy News

By Peggy Garrison  
Community Correspondent

Don Montgomery of Ripley is working with the county. Don was with Tippah Electric Power Association for many years ago and decided retirement wasn't for him. I've missed him since he is no longer with the electric company. Now he gets to spend more time with

his lovely wife and grandson.

Don Cousar is not only the best dry cleaners I know but he also knows cars. My car failed to start several days ago and he was right there to help. I was going to call a service station, but he found my problem in less than a minute. He certainly saved me some money. I've never met anyone as accommodating as he and Linda are. No wonder they have such a thriving business. They are what is known as people person always ready to help their fellow man. God bless you both.

Another people person I know is Amy Smith of Wal-Mart in Ripley. She is a lady who makes shopping a pleasure. Amy has been with Wal-Mart for several years and certainly adds to the great staff there. They're all so helpful

and some stand out a bit more than others. We certainly appreciate all go out of their way to be kind to their customers.

Speaking of those special employees, I spoke with Jamie Simpson there last week. She has been with Wal-Mart for several years in the pharmacy there and I don't get to see her too often. I was friends with her mother for years before she passed away. Adeline was such a

sweet person who left us much too young. She ran a business as long as I knew her and was one of the best. I still miss her so much.

Syble Harkness of the Academy Baptist will celebrate a birthday on April 28th. We hope you have a wonderful day and a blessed year ahead.

Steve Adkins of our neighborhood will mark his special day on May 2nd. Steve is the younger

brother of my friend Pat Cook and I know they will make him a cake. She is one of the best cooks I know. We hope your day is as special as you've always been to us. I won't tell anyone that you are 62 if you don't, okay?

God bless you and all of our friends and neighbors who have meant so much to us over the years. Those who find a faithful friend has a treasure.

Purchase photos that appear in the Southern Sentinel by going to [www.southern-sentinel.com](http://www.southern-sentinel.com).

## Fresh Start with New Conservative Leadership.

We can restore Faith in our country by taking North Mississippi values to Washington.

I'm not a career politician. I will serve the people, not myself and not special interests. It's time for fresh ideas and new conservative leadership.

I understand the people and proudly call North Mississippi home. I'm a product of North Mississippi values. I have a North Mississippi work ethic and backbone.

I'm a true conservative. I'm pro-life, pro-Second Amendment, pro-Christian family values. I support a balanced budget and cutting national debt. I support tax relief for all Americans and a simpler, fairer tax code. I will work to protect our borders and ensure our national security. I will fully fund our military and support our veterans.

Michael P. "Chip" Mills, Jr. is the Itawamba County Prosecutor and Board Attorney for the City of Fulton. Jada teaches biology at Itawamba Community College.

Please Vote Mills on May 12

Chip

2014 Annual Drinking Water Quality Report Town of Poplarville and Water Association PWSID: 0700005 & 0050016 April 2015									
We pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we provide to you. Our primary goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. We have a long history of providing high quality water to the community and we are proud to continue this tradition.									
The source water treatment has been completed for our public water system to determine the overall sustainability of its drinking water supply. This report is designed to inform you about the quality water and services we provide to you. Our primary goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. We have a long history of providing high quality water to the community and we are proud to continue this tradition.									
If you have any questions about this report or drinking water quality, please contact Cotton Mills at 601.927.4343. We will be glad to answer your questions. We are committed to providing you with the highest quality water possible. We will continue to monitor the quality of our water and we will continue to improve the water treatment process. We will continue to provide you with the highest quality water possible. We will continue to monitor the quality of our water and we will continue to improve the water treatment process.									
TEST RESULTS									
Contaminant	Violation	Unit	Level	Range of Levels	Unit	Measurement	MCL	MCL	Unit
<b>Inorganic Contaminants</b>									
10. Barium	N	2015	15	1.6 - 16	ppm	2	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
14. Copper	N	2014	3	0	ppm	1.5	1.5	1.5	Corrosion of household plumbing systems; growth of bacterial organisms; leaching from metal containers.
16. Fluoride	N	2013	12	No Range	ppm	4	4	4	Excess of natural deposits; water additives which promote strong acidic discharge from factories and aluminum refineries.
<b>Disinfection By-Products</b>									
Chlorine	N	2014	3	1.5 - 1	ppm	0	0	0	Water additive used to control disinfection.
TEST RESULTS									
Contaminant	Violation	Unit	Level	Range of Levels	Unit	Measurement	MCL	MCL	Unit
<b>Inorganic Contaminants</b>									
10. Barium	N	2015	15	1.6 - 16	ppm	2	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.

## Obituary

### Eddie Mae Thompson

HICKORY FLAT — Eddie Mae Thompson, 85, died Monday, April 20, 2015, at Clinch County Health and Rehab in New Albany. She was born Nov. 18, 1931, in Benton County. She was a homemaker and a member of Flat Rock Baptist Church.

Services were at 2 p.m. Tuesday, April 22, at Flat Rock Baptist Church with Bro. Bobby Butler, Rev. Gary Vane and Rev. Randy Rouse officiating. Burial was in Flat Rock Cemetery. Holly Springs Funeral Home was in charge of arrangements.

Survivors include one daughter, Susan Thompson of Hickory Flat; four sons, Danny Thompson (Shirley) of Ripley and Eddie Paul Thompson (Dee), Johnny Thompson (Michelle) and Mark Thompson (Tanya), all of Hickory Flat; 11 grandchildren; 10 great-grandchildren.

She was preceded in death by her husband, Donald Wayne Thompson, and her parents, Andy L. Brock and Sarah Mark Brock.

## Briefly

### Singing at Calvary Baptist

There will be a singing at Calvary Baptist Church on Saturday, May 9 beginning at 6 p.m. Everyone is welcome. Bring your song and music and join us for praise.

### Russell to be honored

Hickory Flat Girl Scouts are honoring Eliza Marie Russell with her gold award. Sunday May 3rd from 2 to 3:30 p.m. at the Hickory Flat United Methodist Church. Everyone is welcome cake and beverages will be served.

### Hamilton Baptist homecoming set

Hamilton Baptist Church Homecoming services will begin at 11 a.m. on Sunday, May 3. Guest speakers will be Bro. Greg Gray followed by a pot luck lunch.

### Hickory Flat Head Start currently recruiting

The Institute of Community Services is recruiting children born between Sept. 2, 2010 through Sept. 1, 2012 for the 2015-2016 Head Start school year. Selection will begin in April and May and slots are limited. There is no cost for admission, transportation is free and children are provided with breakfast, lunch and a snack for no charge. For more information, contact Ashland Head Start Center family Service Staff - Kelly Miles, LYNESW at 224-4016.

### Historical Society has books for sale

The Benton County Historical Society has several books for sale. Among those books are "Extraordinary" the story of Henry Coleman of Benton County, the history of the family of Wade Smith Charles and some selections about the Civil War.

### Snow Lake committee seeking vendors

The Snow Lake July 4th Celebration in 2015 will be Saturday, June 27. The July 4th Committee is accepting applications for arts and crafts vendors. Cost for a space is \$25. Food vendors are also sought. Call Cecile Patsano at 662-357-8733 for more information. Political candidates are invited to speak on the day of the event. Contact Cecile Becker by email at becker615@earthlink.net or call Cecile Nighswander at 662-224-5170.

### IGS Headstart recruiting students for 2015 school year

The Institute of Community Services (IGS, Inc.) is recruiting children (ages 3-4) born between September 2, 2010 through September 1, 2012, for the 2015/2016 Head Start School Year. Younger children with disabilities

See Briefs

9A

## POLITICAL DIRECTORY

The Southern Advocate is authorized to announce that the following persons are candidates for office in this year's elections. Names of candidates are listed alphabetically.

**CONSTABLE  
SOUTH HALF  
CLARK McALLUM**

**JUSTICE COURT  
JUDGE (NORTH)  
BRODY CHILDERS**

**JUSTICE COURT  
JUDGE (SOUTH)  
BARRY MCBRIDE**

**SUPERVISOR  
FIFTH DISTRICT  
RICKY PIPKIN**

**SUPERINTENDENT  
OF EDUCATION  
OLLIE MASSENGILL**

**TAX ASSESSOR  
/COLLECTOR  
TOMMY SIMPSON**

The Political directory has to be paid for in advance for this entire election period. No partial payments will be accepted. All political statements should consist of 300 words or less and should be turned in at least two weeks prior to the candidate's deadline for it to be published. No political statements will be published the week before election.

## To The Voters of Third District

It is with sudden regret I must inform you, the wonderful supporters who were backing me in the upcoming Third District Supervisor's race that I am withdrawing my name as candidate for that position.

I have other commitments that I agreed to before I threw my hat in the race. I thought I could fulfill both obligations, but as it has turned out I will not be able to give a hundred percent to either. Therefore, I feel in my heart that I am failing at both. I Pray with all my heart that you will understand the reason why I'm doing this.

Thank You and God Bless you each and every one, Tommy McMullen.

### 2014 Annual Drinking Water Quality Report Town of Fallow/Blacklick Water Association PWS# 0700005 & 0050016

April 2015

We're pleased to present to you the year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of your water and provide you with a copy of your water bill. Our commitment is to provide you with a safe and dependable supply of drinking water. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

The water quality management has been completed for the public water system to determine the overall compliance of its drinking water supply system. The water quality management report contains information on how the water quality management system was implemented and how it was evaluated. The water quality management report is available for viewing upon request. The report for the Town of Fallow has been reviewed and approved by the local health department.

If you have any questions about this report or obtaining your water bill, please contact Office Manager at 662-337-4300. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

We welcome your comments on your drinking water. According to Federal and State laws, this report lists all of the drinking water quality parameters that are required to be reported. The report is designed to inform you about the quality of your water and provide you with a copy of your water bill. Our commitment is to provide you with a safe and dependable supply of drinking water. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

Drinking water is a vital part of our lives. We want you to understand the steps we take to ensure the quality of your water. We make it a priority to ensure the water treatment process and protect your water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Clinch Sand and Ripley Formation Aquifers.

The Family of

# Helen Stroupe

would like to thank each and everyone for the many acts of kindness shown us during her illness, hospitalization and death. We appreciated all of the calls, cards, visits, flowers, food, memorial gifts and your prayers. Many thanks to the doctors, nurses and staff at Baptist Oxford and New Albany Home Choice Health Services staff and Legacy Hospice staff for their excellent care. We are grateful to McBride Funeral Home staff for their care, help, kindness and support given to us. Thank you Bro. Randy Smith and Billy Stroupe for the kind words and support and to Randy and Sandra Wilburn for the beautiful songs. A special thanks to Jolene Gammons, Helen's caregiver and the ladies who prepared the meal. Our family has been blessed with so many friends. Please keep us in your prayers. God Bless Each of You.

Vernon and Rodney Stroupe

## It's All About Watching The Grass Fly

Gravely 160 Series

**\$7,599**

23.50 hp Kawasaki FX730 engine with 3 year compressor warranty  
60" cutting width  
9.8 gal fuel capacity  
7 control levers/shut-off deck with limited lifetime warranty

Gravely ZT50 Model 915150 **\$2,999 or \$59 Month\*\***

Gravely ZT HD52 Model 891083 **\$4,999 or \$98 Month\*\***

23 hp Kawasaki FX730 engine

TEST RESULTS									
Contaminant	Unit	Date Collected	Level Detected	Range of Level Detected	Unit Measurement	MG/L	MCL	Level Source of Contaminant	
<b>Inorganic Contaminants</b>									
10. Barium	ppm	2/11/15	15	14 - 15	ppm	2	2	Discharge of drilling water; discharge from metal refineries; erosion of natural deposits	
11. Copper	ppm	2/11/15	3	3	ppm	1.3	1.3	Discharge of industrial effluent; erosion of natural deposits; erosion of natural deposits	
12. Fluoride	ppm	2/11/15	0.3	No Range	ppm	4	4	Erosion of natural deposits; discharge of industrial effluent; erosion of natural deposits	
<b>Disinfection By-Products</b>									
13. Chlorine	ppm	2/11/15	4	4.0 - 1	ppm	0	MDCL 4	Water additive used to control chlorine	
<b>TEST RESULTS</b>									
Contaminant	Unit	Date Collected	Level Detected	Range of Level Detected	Unit Measurement	MG/L	MCL	Level Source of Contaminant	
<b>Inorganic Contaminants</b>									
10. Barium	ppm	2/11/15	0.2	0.2 - 0.2	ppm	2	2	Discharge of drilling water; discharge from metal refineries; erosion of natural deposits	
11. Copper	ppm	2/11/15	0.4	0.4 - 0.5	ppm	1.3	1.3	Discharge of industrial effluent; erosion of natural deposits; erosion of natural deposits	
12. Fluoride	ppm	2/11/15	0.3	0.3	ppm	4	4	Erosion of natural deposits; discharge of industrial effluent; erosion of natural deposits	